


2021 Water Quality Report for FORD RIVER TOWNSHIP



FORD RIVER LUMBER MILL

This report covers the drinking water quality for Ford River Township, for the calendar year 2020. This information is a snapshot of the quality of the water that we provided to you in 2020. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from two groundwater wells **#2** and **#3**.


The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility of well #1 is very high, while #2 and #3 are rated very low.

For more information about the contents of this report, contact Mark Rose at the township hall 786-8532.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
 - Contaminants that may be present in source water include:
 - **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
 - **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban stormwater runoff, and septic systems.

Ford River Water Quality Data

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.



•

- To ensure that tap water is safe to drink, the USEPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

STATEMENT ABOUT LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ford River Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

VIOLATIONS: *EGLE has required Ford River Water Dept. to state that Ford River had Two Monitoring Violation for failure to collect PFAS and Nitrate samples by 9/30/2021*

Ford River Water has the 2021 CCR posted on their website www.fordriver.org as well as public posting at the Township Hall.

The table below lists all the drinking water contaminants that we detected during the 2020 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2021 the State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:


- Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
 - MC:** Many compounds tested in this group, each have their own EPA assigned MCL and MCLG

Regulated Contaminant	MCL	MCLG	Level Detected	Sampled	Violation Yes / No	Typical Source of Contaminant
-----------------------	-----	------	----------------	---------	--------------------	-------------------------------

For more information about your water, or the contents of this report, leave a message for Michael Smith through the **Township Hall at 786-8532**.

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/

2021 Water Quality Report for FORD RIVER TOWNSHIP



FORD RIVER LUMBER MILL

Fluoride (ppm)	4	4	0.77	2020	No	Erosion of natural deposits. Discharge from fertilizer and aluminum factories.
Barium (ppb)	2000	2000	33	2019	No	Erosion of natural deposits.
Cyanide	0.2	0.2	ND	2019	No	Used in electroplating, steel processing, plastics, synthetic fabrics, fertilizer production; also, from improper waste disposal
Nitrate/Nitrite-N (dw) (ppm)	10	10	ND / ND	2021	No	Erosion of natural deposits, fertilizer use, leaching of septic fields.
Volatile Organic Compounds ppb	MC	MC	0	2019	NO	Enter environment when used to make plastics, dyes, rubbers, polishes, solvents, crude oil, insecticides, inks, varnishes, paints
SOCs (Pest. Herb. Carb. All) ppb	MC	MC	0	2019	NO	Pesticides, herbicides, carbamates
Radioactive Contaminant						
Alpha emitters (pCi/L)	15	0	2.17	2021	No	Erosion of natural deposits
Combined Ra226/228	5	0	3.23	2021	No	Erosion of natural deposits.
Unregulated Contaminant **						
Sodium (ppm)			33	2020	No	Erosion of natural deposits
Contaminant Subject to AL	Action Level	90% of Samples ≤ This Level	Sampled	Number of Samples Above AL	Typical Source of Contaminant	
Lead (ppb)	15	0	2020	0	Distribution piping and fixtures.	
Copper (ppb)	1300	0	2020	0	Distribution piping and fixtures.	

Ford River Water Quality Data

** Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Microbial Contaminants	MCL		Number of Detections	Violation	Source
Total Coliform Bacteria	1 positive monthly sample (Positive in $\geq 5\%$ of samples)	3 each month	0	No	Naturally present in the environment.

We will update this report annually and will keep you informed of any problems that may occur throughout the year as they happen Our water supply has 87 lead service lines and 15 service lines of unknown material out of a total of 192 service lines.

Monitoring and Reporting to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the USEPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2021

We invite public participation in decisions that affect drinking water quality. Ford River Township monthly board meetings are held the second Monday of the month at the township hall. For more information about your water or the contents of this report, contact Michael Smith through the township hall at 906-786-8532 or at www.fordriver.org For more information about safe drinking water, visit the USEPA at <http://www.epa.gov/safewater>.

For more information about your water, or the contents of this report, leave a message for Michael Smith through the **Township Hall at 786-8532**.

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/