

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LI18759**

Official Laboratory Report

Report To: FORD RIVER TOWNSHIP WATER DEPT
1104 SHERIDAN ROAD
ESCANABA MI 49829

System Name/Owner:	FORD RIVER TOWNSHIP WATER DEPT	WSSN/Pool ID:	2350
Collection Address:	3758 L 15 LN WELL HOUSE, BARK RIVER	Source:	TYPE I
Collected By:	MARK A ROSE	Site Code:	CH001
Township/Well#/Section:	FORD RIVER TOWNSHIP/2/	Collector:	Public Water Supply Operator
County:	Delta	Date Collected:	12/07/2018 14:05
Sample Point:	SAMPLE TAP	Date Received:	12/11/2018 13:15
Water System:	Public System Well	Purpose:	Routine Monitoring

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Antimony	Not detected	12/12/2018	0.0006	0.006	EPA 200.8	7440-36-0
Arsenic	Not detected	12/12/2018	0.002	0.010	EPA 200.8	7440-38-2
Barium	0.03	12/12/2018	0.01	2	EPA 200.8	7440-39-3
Beryllium	Not detected	12/12/2018	0.0004	0.004	EPA 200.8	7440-41-7
Cadmium	Not detected	12/12/2018	0.0003	0.005	EPA 200.8	7440-43-9
Chromium	Not detected	12/12/2018	0.01	0.1	EPA 200.8	7440-47-3
Lead	Not detected	12/12/2018	0.001	0.015	EPA 200.8	7439-92-1
Mercury	Not detected	12/12/2018	0.0001	0.002	EPA 200.8	7439-97-6
Nickel	Not detected	12/12/2018	0.01	0.1	EPA 200.8	7440-02-0
Selenium	Not detected	12/12/2018	0.001	0.05	EPA 200.8	7782-49-2
Thallium	Not detected	12/12/2018	0.0002	0.002	EPA 200.8	7440-28-0

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Public Health Delta & Menominee Counties
2920 College Ave.
Escanaba, MI 49829
906 786-9692**

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contact: Scott Hayward